

Wilbourn & McCabe Plumbing Co

1244 Rathgeber Rd
Wichita Falls, TX 76310
940-761-2800
wmcplumbing@yahoo.com
www.wilbournmccabepumbing.com



Estimate

ADDRESS
Clay County Jail Annex

ESTIMATE 45361 - 39
DATE 06/11/2024

SERVICE ADDRESS
Cell 39

DESCRIPTION	AMOUNT
Estimate to replace floor drain that has rusted out. It will be necessary to bust up the concrete to replace it. Repour concrete.	2,500.00
<hr/>	
SUBTOTAL	2,500.00
TAX	0.00
<hr/>	
TOTAL	\$2,500.00

Accepted By

Accepted Date

Wilbourn & McCabe Plumbing Co

1244 Rathgeber Rd
Wichita Falls, TX 76310
940-761-2800
wmcplumbing@yahoo.com
www.wilbournmccabepumbing.com



Estimate

ADDRESS
Clay County Jail Annex

ESTIMATE 45361 - 46
DATE 06/11/2024
EXPIRATION DATE 07/11/2024

SERVICE ADDRESS
Cell 46

DESCRIPTION	AMOUNT
Estimate to replace the hot side button on the pneumatic valve	550.00
*Any unforeseen issues could result in extra costs.	0.00
*Cosmetic repairs, if necessary, are not included in this estimate and will need to be done by others.	0.00
<hr/>	
SUBTOTAL	550.00
TAX	0.00
<hr/>	
TOTAL	\$550.00

Accepted By

Accepted Date

Wilbourn & McCabe Plumbing Co

1244 Rathgeber Rd
Wichita Falls, TX 76310
940-761-2800
wmcplumbing@yahoo.com
www.wilbournmccabep plumbing.com



Estimate

ADDRESS
Clay County Jail Annex

ESTIMATE 45361 - 47
DATE 06/11/2024
EXPIRATION DATE 07/11/2024

SERVICE ADDRESS
Cell 47

DESCRIPTION	AMOUNT
Estimate to replace floor drain cover. It will be necessary to bust up the concrete to replace. We will repour concrete.	2,500.00
*Any unforeseen issues could result in extra costs.	0.00
*Cosmetic repairs, if necessary, are not included in this estimate and will need to be done by others.	0.00
<hr/>	
SUBTOTAL	2,500.00
TAX	0.00
<hr/>	
TOTAL	\$2,500.00

Accepted By

Accepted Date

Wilbourn & McCabe Plumbing Co

1244 Rathgeber Rd
Wichita Falls, TX 76310
940-761-2800
wmcplumbing@yahoo.com
www.wilbournmccabepumbing.com



Estimate

ADDRESS
Clay County Jail Annex

ESTIMATE 45361 - 48
DATE 06/11/2024
EXPIRATION DATE 07/11/2024

SERVICE ADDRESS
Cell 48

DESCRIPTION	AMOUNT
Estimate to replace floor drain cover. It will be necessary to bust up the concrete to replace. Repour concrete.	2,500.00
*Any unforeseen issues could result in extra costs.	0.00
*Cosmetic repairs, if necessary, are not included in this estimate and will need to be done by others.	0.00
<hr/>	
SUBTOTAL	2,500.00
TAX	0.00
<hr/>	
TOTAL	\$2,500.00

Accepted By

Accepted Date

Wilbourn & McCabe Plumbing Co

1244 Rathgeber Rd
Wichita Falls, TX 76310
940-761-2800
wmcplumbing@yahoo.com
www.wilbournmccabepumbing.com



Estimate

ADDRESS
Clay County Jail Annex

ESTIMATE 45361 - 50
DATE 06/11/2024
EXPIRATION DATE 07/11/2024

SERVICE ADDRESS
Cell 50

DESCRIPTION	AMOUNT
Estimate to replace bubbler that is leaking.	400.00
*Any unforeseen issues could result in extra costs.	0.00
*Cosmetic repairs, if necessary, are not included in this estimate and will need to be done by others.	0.00
<hr/>	
SUBTOTAL	400.00
TAX	0.00
<hr/>	
TOTAL	\$400.00

Accepted By

Accepted Date

Wilbourn & McCabe Plumbing Co

1244 Rathgeber Rd
Wichita Falls, TX 76310
940-761-2800
wmcplumbing@yahoo.com
www.wilbourmccabep plumbing.com



Estimate

ADDRESS
Clay County Jail Annex

ESTIMATE 45361 - 51
DATE 06/11/2024
EXPIRATION DATE 07/11/2024

SERVICE ADDRESS
Cell 51

DESCRIPTION	AMOUNT
Estimate to replace cold side stem in lavatory	550.00
Estimate to replace bubbler that is leaking.	400.00
*Any unforeseen issues could result in extra costs.	0.00
*Cosmetic repairs, if necessary, are not included in this estimate and will need to be done by others.	0.00
<hr/>	
SUBTOTAL	950.00
TAX	0.00
<hr/>	
TOTAL	\$950.00

Accepted By

Accepted Date

Wilbourn & McCabe Plumbing Co

1244 Rathgeber Rd
Wichita Falls, TX 76310
940-761-2800
wmcplumbing@yahoo.com
www.wilbournmccabepumbing.com



Estimate

ADDRESS
Clay County Jail Annex

ESTIMATE 45361 - 55
DATE 06/11/2024
EXPIRATION DATE 07/11/2024

SERVICE ADDRESS
Cell 55

DESCRIPTION	AMOUNT
Estimate to replace cold water stem in lavatoyr	550.00
*Any unforeseen issues could result in extra costs.	0.00
*Cosmetic repairs, if necessary, are not included in this estimate and will need to be done by others.	0.00
<hr/>	
SUBTOTAL	550.00
TAX	0.00
<hr/>	
TOTAL	\$550.00

Accepted By

Accepted Date

Wilbourn & McCabe Plumbing Co

1244 Rathgeber Rd
Wichita Falls, TX 76310
940-761-2800
wmcplumbing@yahoo.com
www.wilbournmccabep plumbing.com



Estimate

ADDRESS
Clay County Jail Annex

ESTIMATE 45361 - 59
DATE 06/11/2024
EXPIRATION DATE 07/11/2024

SERVICE ADDRESS
Cell 59

DESCRIPTION	AMOUNT
Lavatory needs a pneumatic valve.	550.00
Estimate to replace drain cover. It will be necessary to bust up the concrete to replace it.	2,500.00
*Any unforeseen issues could result in extra costs.	0.00
*Cosmetic repairs, if necessary, are not included in this estimate and will need to be done by others.	0.00
<hr/>	
SUBTOTAL	3,050.00
TAX	0.00
<hr/>	
TOTAL	\$3,050.00

Accepted By

Accepted Date

Wilbourn & McCabe Plumbing Co

1244 Rathgeber Rd
Wichita Falls, TX 76310
940-761-2800
wmcplumbing@yahoo.com
www.wilbournmccabep plumbing.com



Estimate

ADDRESS
Clay County Jail Annex

ESTIMATE 45361 - 69
DATE 06/11/2024
EXPIRATION DATE 07/11/2024

SERVICE ADDRESS
Cell 69

DESCRIPTION	AMOUNT
Estimate to replace stems on hot water side of lavatory	550.00
<hr/>	
SUBTOTAL	550.00
TAX	0.00
<hr/>	
TOTAL	\$550.00

Accepted By

Accepted Date

Wilbourn & McCabe Plumbing Co

1244 Rathgeber Rd
Wichita Falls, TX 76310
940-761-2800
wmcplumbing@yahoo.com
www.wilbournmccabep plumbing.com



Estimate

ADDRESS
Clay County Jail Annex

ESTIMATE 45361 - 71
DATE 06/11/2024

SERVICE ADDRESS
Cell 72

DESCRIPTION	AMOUNT
Estimate to replace floor drain that has rusted out. It will be necessary to bust up the concrete to replace it. Repour concrete.	2,500.00
SUBTOTAL	2,500.00
TAX	0.00
TOTAL	\$2,500.00

Accepted By

Accepted Date

Wilbourn & McCabe Plumbing Co

1244 Rathgeber Rd
Wichita Falls, TX 76310
940-761-2800
wmcplumbing@yahoo.com
www.wilbournmccabepumbing.com



Estimate

ADDRESS
Clay County Jail Annex

ESTIMATE 45361 - 72
DATE 06/11/2024

SERVICE ADDRESS
Cell 72

DESCRIPTION	AMOUNT
Estimate to replace hot and cold pneumatic valves on lavatory	1,100.00
SUBTOTAL	1,100.00
TAX	0.00
TOTAL	\$1,100.00

Accepted By

Accepted Date