

ASBESTOS BULK ANALYSIS REPORT

Date: September 10, 2024

Flint Inspection Consulting Services, Inc.

Report: 6324-3765
121 N. Main St., Henrietta, TX – Limited

This document shall be considered a duly signed original report of the results obtained from the analysis(es) performed. All analyses are done within government guidelines and regulations.



Gary R. Simmons
Laboratory Manager

Lab Comments on Project: N/A

PLM (Bulk) - Asbestos Analysis Report - Visual ID

EPA 600/R-93/116: Method for the Determination of Asbestos in Bulk Building Materials and EPA – 40 CFR Appendix E to Subpart E of Part 763, Interim Method of the Determination of Asbestos in Bulk Insulation Samples

Flint Inspection Consulting Services, Inc.
 538 Dove Lane,
 Wichita Falls, TX 76301
 940-631-3096
 Contact: Flint Skaggs

Report Number: 6324-3765
 Report Date: September 10, 2024
 Samples Collected: September 9, 2024
 Date Received: September 10, 2024
 Turn-around time: ASAP

Job ID / Site: 121 N. Main St., Henrietta, TX – Limited

Client Sample Number	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Fibrous Type & %	Matrix
1	6324-3765-01A	White / Texture / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	6324-3765-01B	Brown, White / Drywall / Fibrous / Homogeneous	None Detected	Cellulose 10% Fibrous Glass 2%	Binder
2	6324-3765-02A	White / Texture / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	6324-3765-02B	Brown, White / Drywall / Fibrous / Homogeneous	None Detected	Cellulose 10% Fibrous Glass 2%	Binder
3	6324-3765-03A	White / Texture / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	6324-3765-03B	Off White / Joint Tape / Fibrous / Homogeneous	None Detected	Cellulose 95%	Binder
	6324-3765-03C	White / Joint Compound / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	6324-3765-03D	Purple, Brown, White / Drywall / Fibrous / Homogeneous	None Detected	Cellulose 10% Fibrous Glass 2%	Binder
4	6324-3765-04	Blue / Cove Base / NonFibrous / Homogeneous	None Detected	None Detected	Binder
5	6324-3765-05	Blue / Cove Base / NonFibrous / Homogeneous	None Detected	None Detected	Binder

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only represent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

PLM (Bulk) - Asbestos Analysis Report - Visual ID

EPA 600/R-93/116: Method for the Determination of Asbestos in Bulk Building Materials and EPA – 40 CFR Appendix E to Subpart E of Part 763, Interim Method of the Determination of Asbestos in Bulk Insulation Samples

Flint Inspection Consulting Services, Inc.
 538 Dove Lane,
 Wichita Falls, TX 76301
 940-631-3096
 Contact: Flint Skaggs

Report Number: 6324-3765
 Report Date: September 10, 2024
 Samples Collected: September 9, 2024
 Date Received: September 10, 2024
 Turn-around time: ASAP

Job ID / Site: 121 N. Main St., Henrietta, TX – Limited

Client Sample Number	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Fibrous Type & %	Matrix
6	6324-3765-06	Blue / Cove Base / NonFibrous / Homogeneous	None Detected	None Detected	Binder
7	6324-3765-07A	White / 12x12 Floor Tile / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	6324-3765-07B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
8	6324-3765-08A	White / 12x12 Floor Tile / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	6324-3765-08B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
9	6324-3765-09A	White / 12x12 Floor Tile / NonFibrous / Homogeneous	None Detected	None Detected	Binder
	6324-3765-09B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
10	6324-3765-10A	Multi-Colored / Carpet / Fibrous / Homogeneous	None Detected	Synthetic 90%	Binder
	6324-3765-10B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
11	6324-3765-11A	Multi-Colored / Carpet / Fibrous / Homogeneous	None Detected	Synthetic 90%	Binder

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only represent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

PLM (Bulk) - Asbestos Analysis Report - Visual ID

EPA 600/R-93/116: Method for the Determination of Asbestos in Bulk Building Materials and EPA – 40 CFR Appendix E to Subpart E of Part 763, Interim Method of the Determination of Asbestos in Bulk Insulation Samples

Flint Inspection Consulting Services, Inc.
 538 Dove Lane,
 Wichita Falls, TX 76301
 940-631-3096
 Contact: Flint Skaggs

Report Number: 6324-3765
 Report Date: September 10, 2024
 Samples Collected: September 9, 2024
 Date Received: September 10, 2024
 Turn-around time: ASAP

Job ID / Site: 121 N. Main St., Henrietta, TX – Limited

Client Sample Number	Lab Sample Number (by layer)	Color / Description / Fibrous / NonFibrous / Homogeneity	Asbestos Content Type & %	Non-Asbestos Fibrous Type & %	Matrix
11	6324-3765-11B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
12	6324-3765-12A	Multi-Colored / Carpet / Fibrous / Homogeneous	None Detected	Synthetic 90%	Binder
	6324-3765-12B	Yellow / Mastic / NonFibrous / Homogeneous	None Detected	None Detected	Binder
13	6324-3765-13	Grey / Grout / NonFibrous / Homogeneous	None Detected	None Detected	Binder
14	6324-3765-14	Grey / Grout / NonFibrous / Homogeneous	None Detected	None Detected	Binder
15	6324-3765-15	Grey / Grout / NonFibrous / Homogeneous	None Detected	None Detected	Binder
16	6324-3765-16	Black,Brown / Sink Coating / Fibrous / Homogeneous	None Detected	Cellulose 2%	Binder

Analytical results and reports are generated by Apex Precision Analytical Services at the request of and for the exclusive use of the person or entity (client) named on such report. Result, reports or copies of same will not be released by Apex Precision Analytical Services to any third party without the written request from client. These results only represent the materials submitted. Supporting laboratory documentation is available upon request. This report cannot be used to represent conditions at any other location, date or time and does not imply that this space is free from these or any other contaminants. No responsibility or liability is assumed for the manner in which these results are used or interpreted. This must not be used to claim product endorsement by NVLAP or any government agency of the United States. Apex Precision Analytical Services reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.